

Willingboro Municipal Utilities Authority

433 JOHN F. KENNEDY WAY
WILLINGBORO, NEW JERSEY 08046-2119

Telephone (609) 877-2900
Fax (609) 835-4645

COMMISSIONERS
Carl Turner, Chairman
Darvis Holley, Vice Chairman
T. Wayne Scott
Patricia Lindsay-Harvey
Webster Evans
Kevin McIntosh, 1st Alt.
James Boyer, 2nd Alt.

EXECUTIVE DIRECTOR
Andrew Weber

May 14, 2021

Water Main materials
Addendum number 1

Attention all bidders.

Item number 1

The end date of the contract will no longer be June 2nd, 2022. **The Authority has changed the end date of the contract to May 31st, 2022.**

Item number 2

The bid opening is no longer 5.17.21. **The Authority has changed the date of the bid opening to 5.18.21, same time, 11:00am.**

Item number 3

Question 1: For the DIP, Class B, is that Class 52 (thickness) pipe (Spec #322- #335)?

Answer: **Yes, Class 52 Thickness**

Question 2: For the Cold Patch, is that 2 tons in bags or delivered by truck to yard (Spec item #107)?

Answer: **Truck Load**

Item number 4

Question 3: What are the dimensions of the manhole risers/grade rings needed (Spec item #208)?

Answer: **Outside dimension 60". Inside dimension 24". Thickness 2"**

Item number 5

The following statement should replace #17, Time of Completion, on page IB-5 as:

"17. TIME OF COMPLETION. Delivery of material furnished under this contract shall be completed no later than Forty-Five (45) days following issuance of any purchase order issued during the contract period of June 1, 2021 to May 31, 2022."

We look forward to getting your bid and would like to apologize for any inconvenience this error may have caused.

Sincerely,

Emmanuel Stuppard
Operations Director